



Form D 7.2

Distribution Losses

Sl. No.	Name of the Distribution Area	Voltage	No. of Transformers		Total Capacity (kVA)	Total Connected Load (kW)	Total Demand (kW)	Losses (kW)	Losses (% of Total Demand)	Total Commercial Losses (% of Energy Input)			
			1	2									
	Jodhpur CC	11 kV	390	390	1830.13	903.69	569.39	1473.08	266.22	14.55%	NA	NA	NA
	Jodhpur DC	11 kV	2196	2072	5866.55	3484.86	395.78	3880.64	2043.27	34.83%	NA	NA	NA
	Pali	11 kV	761	761	1395.99	851.88	345.68	1197.56	220.30	15.78%	NA	NA	NA
	Sirohi	11 kV	367	367	933.67	517.30	309.45	826.75	124.47	13.33%	NA	NA	NA
	Jalore	11 kV	1118	1118	2270.08	1605.25	242.94	1848.19	397.14	17.49%	NA	NA	NA
	Barnet	11 kV	1122	1086	1875.63	1365.78	315.90	1681.68	282.30	15.05%	NA	NA	NA
	Jaisalmer	11 kV	405	405	1093.92	698.43	165.46	863.89	212.65	19.44%	NA	NA	NA
	Bikaner CC	11 kV	162	162	844.76	0.00	792.57	792.57	46.65	5.52%	NA	NA	NA
	Bikaner DC	11 kV	1391	1355	4265.64	2817.42	200.95	3018.37	1216.21	28.51%	NA	NA	NA
	Hanumangarh	11 kV	577	556	1373.02	1086.38	114.25	1200.63	201.81	14.70%	NA	NA	NA
	Sri Ganganagar	11 kV	569	569	1388.75	892.63	244.24	1136.87	248.49	17.89%	NA	NA	NA
	Churu	11 kV	748	690	2233.40	1452.40	132.50	1584.90	606.90	27.17%	NA	NA	NA
	Jodhpur Discom		9806	9531	25372	15676.03	3829.08	19505.11	5866.42	23.12%	NA	NA	NA

(31)  
 SUPRINTENDING ENGINEER (PARC)  
 JODHPUR DISCOM, JODHPUR

101

