

Form D 6.2

Improvement in performance

Name of Distribution Licensee JdVVNL
 Licensed Area of Supply Jodhpur Discom

S.No.	Particulars	Ref	FY 2017-18		FY 2018-19		FY 2019 - 20		Remarks
			Actuals	4	Provisionals	5	Projected	6	
1	2	3	4	5	6	7			
1	Distribution Losses, (%)		19.33%	23.12%	18.00%				
2	Collection Efficiency, (%)		95.00%	100%	100%				
3	Distribution losses (%)								
(a)	Urban areas with population exceeding 1 lakh		9.74%						
(b)	Industrial areas of load exceeding 5MVA		NA						
(c)	Rural areas		21.87%						
4 (a)	Percentage of consumers billed		100.00%	100%	100%				100%
4 (b)	Revenue realisation, (Rs Cr)		12,071.93	12322.06	13122.19				
5	Stopped Meters %								
6 (a)	Defective meters/ metering arrangement%								
6 (b)	Replacement of Defective meters, %		57.78%						
7	Un-metered consumers (%)								
(a)	Agricultural		11.00%	10.16%	8.18%				
(b)	Others								
8	System availability %		99.99%	100%	100%				100%
9	Transformer failure rate								
a	Distribution transformers (%)		7.92%						
b	Power transformers (%)		6.84%						