



VIDYUT VITRAN NIGAM LTD.

Corporate Identity Number (CIN) -U40109RJ2000SGC016483

Regd. Office : New Power House, Jodhpur- 342003

Phone No : 0291-2742227 Fax No : 0291-5106366

E-mail : seracomml@gmail.com Web site : energy.rajasthan.gov.in/jdvynl

No.JdVVNL/ SE(RA&C)/JU/S.RA/2019-20/D.

65

Dt. 12.04.19

The Secretary,
Rajasthan Electricity Regulatory Commission,
Vidhyut Viniyamak Bhawan,
Near State Motor Garage,
Sahakar Marg,
Jaipur

Sub.: Compliance of BRAP-2019 points related to Energy Department.

Ref. : Point No. 49(i) of the BRAP- 2019.

On the subjected cited above, it is submitted that in compliance of the point No. 49(i) of the BRAP-2019 (Copy enclosed) pertaining to the Energy Department wherein it is mentioned that "Ensure that the State/UT Regulator publishes monthly data regarding total duration and frequency of power outage on line in public domain". The above information shall be published by 15th of every month.

Therefore, in compliance of the aforesaid point, the data for the month of February- 2019 of Jodhpur Discom is submitted via mail on your email id : recjpr@yahoo.co.in & rercccommon@yahoo.com for publishing on Hon'ble RERC's website by 15th of month.


(U. S. CHOUHAN)

**SUPERINTENDING ENGINEER (RA&C)
JODHPUR DISCOM, JODHPUR**

Distribution SOP Reporting Formats
Reliability Indices

System Average Interruption Frequency Index (SAIFI)

Name of Licensee: JODHPUR DISCOM

SOP-4
 For the month of February, 2019

S.No.	Name of Circle	Total number of consumers served		Total number of sustained interruptions to consumers	SAIFI = (2)/(1) (Number of Interruptions/ consumer)	Target specified by the Commission
		1	2			
1	JODHPUR, CC	277653	1012854	3.65		
2	JODHPUR, DC	464943	1925412	4.14		
3	PALI	517978	1312547	2.53		
4	SIROHI	227227	1045896	4.60		
5	BARMER	430783	3558796	8.26		
6	JALORE	338069	1645784	4.87		
7	JAISALMER	118300	454785	3.84		
8	BKESL (BIKANER CC)	162803	246987	1.52		
9	BIKANER, DC	251986	2547894	10.11		
10	HANUMANGARH	374033	1541785	4.12		
11	GANGANAGAR	384211	1897954	4.94		
12	CHURU	375508	2974562	7.92		
TOTAL		3923494	20165256	5.14		

Note:

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.

Distribution SOP Reporting Formats

Reliability Indices

System Average Interruption Duration Index (SAIDI)

Name of Licensee: JODHPUR DISCOM

SOP-5

For the month of February, 2019

S.No.	Name of Circle	Total number of consumers served	Total minutes of sustained interruptions to consumers	SAIDI = (2)/(1)		Target specified by the Commission
				1	(Minutes/ consumer)	
1	JODHPUR, CC	277653	1295874	4.67		
2	JODHPUR, DC	464943	2885496	6.21		
3	PALI	517978	3054778	5.90		
4	SIROHI	227227	1158974	5.10		
5	BARMER	430783	4458411	10.35		
6	JALORE	338069	2208729	6.53		
7	JAISALMER	118300	556987	4.71		
8	BKESL (BIKANER CC)	162803	2265478	13.92		
9	BIKANER, DC	251986	3641864	14.45		
10	HANUMANGARH	374033	1652778	4.42		
11	GANGANAGAR	384211	2012789	5.24		
12	CHURU	375508	3174694	8.45		
	TOTAL	3923494	28366852	7.23		

Note:

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.

1874