



JODHPUR VIDYUT VITRAN NIGAM LTD.

Corporate Identity Number (CIN) -U40109RJ2000SGC016483

Regd. Office : New Power House, Jodhpur- 342003

Phone No : 0291-2742227 Fax No : 0291-5106366

E-mail : seracomml@yahoo.com Web site : energy.rajasthan.gov.in/jdvvn

No.JdVVNL/ SE(RA&C)/JU/S.RA/ /2019-20/D.

156

Dt. 02.05.19

The Secretary,
Rajasthan Electricity Regulatory Commission,
Vidhyut Viniyamak Bhawan,
Near State Motor Garage,
Sahakar Marg,
Jaipur.

Sub.: Compliance of BRAP-2019 points related to Energy Department.

Ref.: Point No. 49(i) of the BARP-2019.

On the subject cited above, it is submitted that in compliance of the point no. 49(i) of the BARP-2019 pertaining to the Energy Department wherein it is mentioned that "Ensure that the Stat/UT Regulator publishes monthly data regarding total duration and frequency of power outage on line in public domain". The above information shall be published by 15th of every month.

Therefore, in compliance of the aforesaid point, the data for the month of March-2019 of Jodhpur Discom is submitted herewith for publishing on Hon'ble RERC's website.

(31/5/19)

(U. S. CHOUHAN)

SUPERINTENDING ENGINEER(RA&C)
JODHPUR DISCOM, JODHPUR

Distribution SOP Reporting Formats

Reliability Indices

System Average Interruption Frequency Index (SAIFI)

Name of Licensee: JODHPUR DISCOM

SOP-4

For the month of March, 2019

S.No.	Name of Circle	Total number of		SAIFI = (2)/(1) (Number of Interruptions/ consumer)	Target specified by the Commission
		consumers served	sustained interruptions to consumers		
		1	2		
1	JODHPUR, CC	278835	1047154	3.76	
2	JODHPUR, DC	467898	1949655	4.17	
3	PAJI	520352	1231486	2.37	
4	SIROHI	229483	1012878	4.41	
5	BARMER	434903	3544280	8.15	
6	JALORE	342840	1825479	5.32	
7	JALSALMER	119898	370107	3.09	
8	BKESL (BIKANER CC)	162943	170967	1.05	
9	BIKANER, DC	254986	2504920	9.82	
10	HANUMANGARH	377089	1365186	3.62	
11	GANGANAGAR	386278	1482405	3.84	
12	CHURU	377025	3299567	8.75	
	TOTAL	3952530	19804084	5.01	

Note:

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.

Distribution SOP Reporting Formats
Reliability Indices

System Average Interruption Duration Index (SAIDI)

SOP-5
For the month of March, 2019

Name of Licensee: JODHPUR DISCOM

S.No.	Name of Circle	Total number of consumers served	Total minutes of sustained interruptions to consumers	SAIDI = (2)/(1)		Target specified by the Commission
				1	(Minutes/ consumer)	
1	JODHPUR, CC	278835	1234874	4.43		
2	JODHPUR, DC	467898	2341661	5.00		
3	PAI, J	520352	2967350	5.70		
4	SIROHI	229483	1111205	4.84		
5	BARMER	434903	4536895	10.43		
6	JALORE	342840	2256784	6.58		
7	JAISALMER	119898	602251	5.02		
8	BKESL (BIKANER CC)	162943	2098517	12.88		
9	BIKANER, DC	254986	3823792	15.00		
10	HANUMANGARH	377089	1871768	4.96		
11	GANGANAGAR	386278	1600581	4.14		
12	CHURU	377025	2722433	7.22		
	TOTAL	3952530	27168111	6.87		

Note:

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.