



JODHPUR VIDYUT VITRAN NIGAM LTD.

Corporate Identity Number (CIN) -U40109RJ2000SGC016483

Regd. Office : New Power House, Jodhpur- 342003

Phone No : 0291-2742227 Fax No : 0291-5106366

E-mail : seracomml@yahoo.com Web site : energy.rajasthan.gov.in/idvvni

No.JdVVNL/ SE(RA&C)/JU/S.RA/ /2019-20/D.

310

Di. 24/5/19

The Secretary,
Rajasthan Electricity Regulatory Commission,
Vidhyut Viniyamak Bhawan,
Near State Motor Garage,
Sahakar Marg,
Jaipur.

Sub.: Compliance of BRAP-2019 points related to Energy Department.

Ref.: Point No. 49(i) of the BARP-2019.

On the subject cited above, it is submitted that in compliance of the point no. 49(i) of the BARP-2019 pertaining to the Energy Department wherein it is mentioned that "Ensure that the State/UT Regulator publishes monthly data regarding total duration and frequency of power outage on line in public domain".

Therefore, in compliance of the aforesaid point, the data for the month of April-2019 of Jodhpur Discom is submitted herewith for publishing on Commission's website.


(U. S. CHOUHAN)

**SUPERINTENDING ENGINEER(RA&C)
JODHPUR DISCOM, JODHPUR**

O/c

Distribution SOP Reporting Formats

Reliability Indices**System Average Interruption Frequency Index (SAIFI)**

Name of Licensee: JODHPUR DISCOM

SOP-4

For the month of **APRIL**, 2019

| S.No. | Name of Circle | Total number of consumers served | Total number of sustained interruptions to consumers | SAIFI = (2)/(1) (Number of Interruptions/ consumer) | Target specified by the Commission |
|--------------|--------------------|----------------------------------|--|---|------------------------------------|
| | | 1 | 2 | | |
| 1 | JODHPUR, CC | 279334 | 1057462 | 3.79 | |
| 2 | JODHPUR, DC | 468803 | 2035520 | 4.34 | |
| 3 | PALI | 522003 | 1232288 | 2.36 | |
| 4 | SIROHI | 229863 | 1012846 | 4.41 | |
| 5 | BARMER | 435942 | 3552722 | 8.15 | |
| 6 | JALORE | 344076 | 1490158 | 4.33 | |
| 7 | JAISALMER | 120088 | 370126 | 3.08 | |
| 8 | BKESL (BIKANER CC) | 159783 | 946637 | 5.92 | |
| 9 | BIKANER, DC | 255106 | 2600510 | 10.19 | |
| 10 | HANUMANGARH | 377708 | 1396895 | 3.70 | |
| 11 | GANGANAGAR | 387334 | 1670543 | 4.31 | |
| 12 | CHURU | 377941 | 4299567 | 11.38 | |
| TOTAL | | 3957981 | 21665274 | 5.47 | |

Note:

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.

Distribution SOP Reporting Formats

Reliability Indices**System Average Interruption Duration Index (SAIDI)**

Name of Licensee: JODHPUR DISCOM

SOP-5

For the month of *APRIL*, 2019

| S.No. | Name of Circle | Total number of consumers served | Total minutes of sustained interruptions to consumers | SAIDI = (2)/(1) | Target specified by the Commission |
|-------|--------------------|----------------------------------|---|---------------------|------------------------------------|
| | | 1 | 2 | (Minutes/ consumer) | |
| 1 | JODHPUR. CC | 279334 | 1237413 | 4.43 | |
| 2 | JODHPUR. DC | 468803 | 2841600 | 6.06 | |
| 3 | PALI | 522003 | 3011539 | 5.77 | |
| 4 | SIROHI | 229863 | 1111739 | 4.84 | |
| 5 | BARMER | 435942 | 4682280 | 10.74 | |
| 6 | JALORE | 344076 | 4678587 | 13.60 | |
| 7 | JAISALMER | 120088 | 602318 | 5.02 | |
| 8 | BKESL (BIKANER CC) | 159783 | 2122594 | 13.28 | |
| 9 | BIKANER. DC | 255106 | 3827889 | 15.01 | |
| 10 | HANUMANGARH | 377708 | 1886615 | 4.99 | |
| 11 | GANGANAGAR | 387334 | 1822796 | 4.71 | |
| 12 | CHURU | 377941 | 2722533 | 7.20 | |
| | TOTAL | 3957981 | 30547903 | 7.72 | |

Note:

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.