



JODHPUR VIDYUT VITRAN NIGAM LTD.

Corporate Identity Number (CIN) -U40109RJ2000SGC016483

Regd. Office : New Power House, Jodhpur- 342003

Phone No : 0291-2742227

E-mail : seracomml@yahoo.com Web site : energy.rajasthan.gov.in/jdvvn/

No.JdVVNL/ SE(RA&C)/JU/S.RA/ /2019-20/D. 522 Dt. 27.06.19

The Secretary,
Rajasthan Electricity Regulatory Commission,
Vidhyut Viniyamak Bhawan,
Near State Motor Garage,
Sahakar Marg,
Jaipur.

Sub.: Compliance of BRAP-2019 points related to Energy Department.

Ref.: Point No. 49(i) of the BARP-2019.

On the subject cited above, it is submitted that in compliance of the point no. 49(i) of the BARP-2019 pertaining to the Energy Department wherein it is mentioned that "Ensure that the State/UT Regulator publishes monthly data regarding total duration and frequency of power outage on line in public domain".

Therefore, in compliance of the aforesaid point, the data for the month of May-2019 of Jodhpur Discom is submitted herewith for publishing on Commission's website.


(U. S. CHOUHAN)

**SUPERINTENDING ENGINEER(RA&C)
JODHPUR DISCOM, JODHPUR**

Copy to the Superintending Engineer (IT), Jodhpur Discom, Jodhpur for publishing on Nigam's website.


**SUPERINTENDING ENGINEER(RA&C)
JODHPUR DISCOM, JODHPUR**

Distribution SOP Reporting Formats

Reliability Indices**System Average Interruption Frequency Index (SAIFI)**

Name of Licensee: JODHPUR DISCOM

SOP-4

For the month of May, 2019

S.No.	Name of Circle	Total number of consumers served	Total number of sustained interruptions to consumers	SAIFI = (2)/(1) (Number of Interruptions/ consumer)	Target specified by the Commission
		1	2		
1	JODHPUR, CC	279774	1079684	3.86	
2	JODHPUR, DC	471466	2062963	4.38	
3	PALI	524509	1292349	2.46	
4	SIROHI	230449	1598978	6.94	
5	BARMER	439641	2488367	5.66	
6	JALORE	345652	1490158	4.31	
7	JAISALMER	120606	391362	3.24	
8	BKESL (BIKANER CC)	158909	1066910	6.71	
9	BIKANER, DC	255860	2642050	10.33	
10	HANUMANGARH	380190	1954216	5.14	
11	GANGANAGAR	389402	1908764	4.90	
12	CHURU	378357	4301523	11.37	
TOTAL		3974815	22277324	5.60	

Note:

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.

Distribution SOP Reporting Formats

Reliability Indices**System Average Interruption Duration Index (SAIDI)**

SOP-5

Name of Licensee: JODHPUR DISCOM

For the month of May, 2019

S.No.	Name of Circle	Total number of consumers served	Total minutes of sustained interruptions to consumers	SAIDI = (2)/(1)	Target specified by the Commission
		1	2	(Minutes/ consumer)	
1	JODHPUR, CC	279774	1241658	4.44	
2	JODHPUR, DC	471466	2561375	5.43	
3	PALI	524509	3012013	5.74	
4	SIROHI	230449	1111596	4.82	
5	BARMER	439641	8900404	20.24	
6	JALORE	345652	4687988	13.56	
7	JAISALMER	120606	610217	5.06	
8	BKESL (BIKANER CC)	158909	1099704	6.92	
9	BIKANER, DC	255860	3839133	15.00	
10	HANUMANGARH	380190	1892635	4.98	
11	GANGANAGAR	389402	1852316	4.76	
12	CHURU	378357	2731852	7.22	
TOTAL		3974815	33540891	8.44	

Note:

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.