



# JODHPUR VIDYUT VITRAN NIGAM LTD.

Corporate Identity Number (CIN) -U40109RJ2000SGC016483

Regd. Office New Power House, Jodhpur- 342003

Phone No : 0291-2742227

E-mail [seracomml@yahoo.com](mailto:seracomml@yahoo.com) Web site [energy.rajasthan.gov.in/jdvvn1](http://energy.rajasthan.gov.in/jdvvn1)

No.JdVVNL/ SE(RA&C)/JU/S.RA/ /2019-20/D

778

DI. 31.07.19

The Secretary,  
Rajasthan Electricity Regulatory Commission,  
Vidhyut Viniyamak Bhawan,  
Near State Motor Garage,  
Sahakar Marg,  
Jaipur.

**Sub.:** Compliance of BRAP-2019 points related to Energy Department.

**Ref.:** Point No. 49(i) of the BARP-2019.

On the subject cited above, it is submitted that in compliance of the point no. 49(i) of the BARP-2019 pertaining to the Energy Department wherein it is mentioned that "Ensure that the State/UT Regulator publishes monthly data regarding total duration and frequency of power outage on line in public domain".

Therefore, in compliance of the aforesaid point, the data for the month of June-2019 of Jodhpur Discom is submitted herewith for publishing on Commission's website.

(U. S. CHOUHAN)

SUPERINTENDING ENGINEER(RA&C)  
JODHPUR DISCOM, JODHPUR

Copy to the Superintending Engineer (IT), Jodhpur Discom, Jodhpur for publishing on Nigam's website.

SUPERINTENDING ENGINEER(RA&C)  
JODHPUR DISCOM, JODHPUR

Distribution SOP Reporting Formats

**Reliability Indices**

**System Average Interruption Frequency Index (SAIFI)**

Name of Licensee: JODHPUR DISCOM

SOP-4

For the month of June, 2019

S No.	Name of Circle	Total number of consumers served	Total number of sustained interruptions to consumers	SAIFI = (2)/(1) (Number of Interruptions/ consumer)	Target specified by the Commission
		1	2		
1	JODHPUR, CC	281147	1178743	4.19	
2	JODHPUR, DC	475954	2189806	4.60	
3	PALI	528306	1380986	2.61	
4	SIROHI	232153	1633754	7.04	
5	BARMER	447401	2591868	5.79	
6	JALORE	349503	1536987	4.40	
7	JAISALMER	121830	408431	3.35	
8	BKESL (BIKANER CC)	159518	962916	6.04	
9	BIKANER DC	258439	2633231	10.19	
10	HANUMANGARH	382106	2460984	6.44	
11	GANGANAGAR	392842	1989124	5.06	
12	CHURU	381166	4299567	11.28	
<b>TOTAL</b>		<b>4010365</b>	<b>23266397</b>	<b>5.80</b>	

Note

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.

Distribution SOP Reporting Formats

**Reliability Indices**

**System Average Interruption Duration Index (SAIDI)**

**SOP-5**

**Name of Licensee: JODHPUR DISCOM**

**For the month of June, 2019**

S.No.	Name of Circle	Total number of consumers served	Total minutes of sustained interruptions to consumers	SAIDI = (2)/(1)	Target specified by the Commission
		1	2	(Minutes/ consumer)	
1	JODHPUR, CC	281147	1337352	4.76	
2	JODHPUR, DC	475954	2863167	6.02	
3	PALI	528306	3664289	6.94	
4	SIROHI	232153	1210961	5.22	
5	BARMER	447401	8836160	19.75	
6	JALORE	349503	4698758	13.44	
7	JAISALMER	121830	819883	6.73	
8	BKESL (BIKANER CC)	159518	859173	5.39	
9	BIKANER, DC	258439	3977092	15.39	
10	HANUMANGARH	382106	2095670	5.48	
11	GANGANAGAR	392842	1976165	5.03	
12	CHURU	381166	2722633	7.14	
<b>TOTAL</b>		<b>4010365</b>	<b>35061303</b>	<b>8.74</b>	

Note

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.