



JODHPUR VIDYUT VITRAN NIGAM LTD.

Corporate Identity Number (CIN) -U40109RJ2000SGC016483

Regd Office New Power House, Jodhpur- 342003

Phone No 0291-2742227

E-mail seiacomml@yahoo.com Web site energy.rajasthan.gov.in/jdvvn1

No JdVVNL/ SE(RA&C)/JU/S RA/ /2019-20/D 931

Dt. 27/08/2019

The Secretary,
Rajasthan Electricity Regulatory Commission,
Vidhyut Viniyamak Bhawan,
Near State Motor Garage,
Sahakar Marg,
Jaipur.

Sub.: Compliance of BRAP-2019 points related to Energy Department.

Ref.: Point No. 49(i) of the BARP-2019.

On the subject cited above, it is submitted that in compliance of the point no. 49(i) of the BARP-2019 pertaining to the Energy Department wherein it is mentioned that "Ensure that the State/UT Regulator publishes monthly data regarding total duration and frequency of power outage on line in public domain"

Therefore, in compliance of the aforesaid point, the data for the month of July-2019 of Jodhpur Discom is submitted herewith for publishing on Commission's website.

(U. S. CHOUHAN)

**SUPERINTENDING ENGINEER(RA&C)
JODHPUR DISCOM, JODHPUR**

Copy to the Superintending Engineer (IT), Jodhpur Discom, Jodhpur for publishing on Nigam's website

**SUPERINTENDING ENGINEER(RA&C)
JODHPUR DISCOM, JODHPUR**

Distribution SOP Reporting Formats

Reliability Indices**System Average Interruption Frequency Index (SAIFI)**

Name of Licensee: JODHPUR DISCOM

SOP-4

For the month of July, 2019

S.No.	Name of Circle	Total number of consumers served	Total number of sustained interruptions to consumers	SAIFI = (2)/(1) (Number of Interruptions/ consumer)	Target specified by the Commission
		1	2		
1	JODHPUR, CC	281735	1196224	4.25	
2	JODHPUR, DC	479880	2245835	4.68	
3	PALI	530169	1405489	2.65	
4	SIROHI	232981	1659473	7.12	
5	BARMER	452366	2698392	5.97	
6	JALORE	350159	1632811	4.66	
7	JAISALMER	122165	470615	3.85	
8	BKESL (BIKANER CC)	160182	1071813	6.69	
9	BIKANER, DC	259908	2631153	10.12	
10	HANUMANGARH	383119	2498975	6.52	
11	GANGANAGAR	394047	1998944	5.07	
12	CHURU	382029	4314564	11.29	
TOTAL		4028740	23824288	5.91	

Note

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.

Distribution SOP Reporting Formats

Reliability Indices

System Average Interruption Duration Index (SAIDI)

SOP-5

Name of Licensee: JODHPUR DISCOM

For the month of July, 2019

S.No.	Name of Circle	Total number of consumers served	Total minutes of sustained interruptions to consumers	SAIDI = (2)/(1)	Target specified by the Commission
		1	2	(Minutes/ consumer)	
1	JODHPUR, CC	281735	1398416	4.96	
2	JODHPUR, DC	479880	2894243	6.03	
3	PALI	530169	3702548	6.98	
4	SIROHI	232981	1254220	5.38	
5	BARMER	452366	8993883	19.88	
6	JALORE	350159	4771258	13.63	
7	JAISALMER	122165	842764	6.90	
8	BKESL (BIKANER CC)	160182	953966	5.96	
9	BIKANER, DC	259908	4060851	15.62	
10	HANUMANGARH	383119	2200543	5.74	
11	GANGANAGAR	394047	2054240	5.21	
12	CHURU	382029	2735214	7.16	
TOTAL		4028740	35862146	8.90	

Note

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.