

Distribution SOP Reporting Formats

Reliability Indices**System Average Interruption Frequency Index (SAIFI)**

Name of Licensee: JODHPUR DISCOM

SOP-4

For the month of August, 2019

S.No.	Name of Circle	Total number of consumers served	Total number of sustained interruptions to consumers	SAIFI = (2)/(1) (Number of Interruptions/ consumer)	Target specified by the Commission
		1	2		
1	JODHPUR, CC	282251	1083443	3.84	
2	JODHPUR, DC	482923	2038964	4.22	
3	PALI	517623	1302289	2.52	
4	SIROHI	234094	1515305	6.47	
5	BARMER	459824	2517888	5.48	
6	JALORE	354081	1522912	4.30	
7	JAISALMER	122865	448269	3.65	
8	BKESL (BIKANER CC)	160751	1257724	7.82	
9	BIKANER, DC	261382	2630717	10.06	
10	HANUMANGARH	385142	2449924	6.36	
11	GANGANAGAR	395855	1563007	3.95	
12	CHURU	383292	4299570	11.22	
TOTAL		4040083	22630012	5.60	

Note

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.

Distribution SOP Reporting Formats

Reliability Indices

System Average Interruption Duration Index (SAIDI)

SOP-5

Name of Licensee: JODHPUR DISCOM

For the month of August, 2019

S.No.	Name of Circle	Total number of consumers served	Total minutes of sustained interruptions to consumers	SAIDI = (2)/(1)	Target specified by the Commission
		1	2	(Minutes/ consumer)	
1	JODHPUR, CC	282251	1313352	4.65	
2	JODHPUR, DC	482923	2589341	5.36	
3	PALI	517623	3317577	6.41	
4	SIROHI	234094	1103115	4.71	
5	BARMER	459824	7592145	16.51	
6	JALORE	354081	4781220	13.50	
7	JAISALMER	122865	661259	5.38	
8	BKESL (BIKANER CC)	160751	1219225	7.58	
9	BIKANER, DC	261382	2819161	10.79	
10	HANUMANGARH	385142	1899793	4.93	
11	GANGANAGAR	395855	1617014	4.08	
12	CHURU	383292	2722628	7.10	
TOTAL		4040083	31635830	7.83	

Note

An interruption in supply to a consumer shall be considered as one interruption to one consumer. In case of failure of a line or transformer number of interruption shall be equal to the number of consumers affected.