



R.E.O.-160

JODHPUR VIDYUT VITRAN NIGAM LIMITED

New Power House Premises, Jodhpur

Phone: 0291-2742231, Fax: 0291-2742231

No. JdVVNL/CF(C&P)/JU/S.S&I/D. 1219 Jodhpur, Dt. 09.07.2008

ORDER

While execution of work for releasing Ag. Connection to Second Phase applicants whom Demand Notices are to be issued (Actual dates shall be intimated in due course) and to ensure proper quality with good workmanship, the following instructions are to be strictly adhered to, regarding installation of transformers, erection of lines etc.:-

1. If there is only one connection in the existing 25KVA/40KVA transformer and capacity of transformer permits, then the new proposed connection will be released from same Sub-station by replacing the existing one meter-transformer by two meters transformer.
2. In all other cases not covered by item No.1 above, an individual transformer for each Ag. Consumer will be installed as under :-

(i)	Connection upto 7.5 HP	10 KVA, 3 Phase Transformer on 9M Pole
(ii)	Connection above 7.5 HP & upto 12.5 HP	16 KVA, 3 Phase Transformer on 9M Pole
(iii)	Connection above 12.5 HP & upto 20 HP	25 KVA, 3 Phase Transformer on 8M Pole D.P. Structure
(iv)	Connection above 20 HP & upto 32 HP	40 KVA, 3 Phase Transformer on 8M Pole D.P. Structure

An undertaking in the prescribed format enclosed at (Annexure-'B') is compulsorily to be obtained from each and every consumer & kept in the office record safely.

3. All 10 KVA & 16 KVA transformers shall be installed in such a way that the transformer should be 5 Mtr.(Five Meters) above from ground level and shall be properly welded with steel structure and also bolted

with anti-theft fasteners (bolts-nuts) so as to avoid the possibility of theft.

4. The span for both HT/LT over head lines with 8/9 Meters long 200 Kg. working load PCC Poles is to be kept 60 to 70 Meters.
5. There should be proper guarding on all road crossing, telephone line crossing, inter line crossings of all voltages and lines erected near public place and busy area.

(V.S. SHARMA)

(V.S.SHARMA)

CHIEF ENGINEER(Comml.& Plan)
JODHPUR DISCOM: JODHPUR:

Copy to the following for information & necessary action :-

- 1). Secretary(Energy), Govt. of Rajasthan, Jaipur.
- 2). Chairman & Managing Director, Jaipur Discom, Jaipur.
- 3). Managing Director, Ajmer Discom, Ajmer.
- 4). Director(Finance), Jodhpur Discom, Jodhpur.
- 5). Zonal Chief Engineer(JZ/BZ), Jodhpur Discom, Jodhpur/Bikaner.
- 6). Chief Accounts Officer, Jodhpur Discom, Jodhpur.
- 7). Secretary(Admn.), Jodhpur Discom, Jodhpur.
- 8). Superintending Engineer(), Jodhpur Discom, _____
- 9). Addl. Superintendent of Police(VIG), Jodhpur Discom, Jodhpur.
- 10). TA to Managing Director, Jodhpur Discom, Jodhpur.
- 11). Company Secretary, Jodhpur Discom, Jodhpur.
- 12). Sr.Accounts Officer(Revenue/Audit), Jodhpur Discom, Jodhpur.
- 13). Public Relation Officer, Jodhpur Discom, Jodhpur.
- 14). P.T. to Energy Minister, Govt.of Rajasthan, Jaipur for information and necessary action please.

(V.S. SHARMA)

CHIEF ENGINEER(Comml.& Plan)
JODHPUR DISCOM: JODHPUR: