

RAJASTHAN SOLARPARK DEVELOPMENT COMPANY LIMITED

(A Govt. of Rajasthan undertaking)

(CIN NO. U40102RJ2011SGC036861)

Reg. Office: E-166, Yudhishtir Marg, C-Scheme, Jaipur-302001

Tel: 2225859, 2229341 email: solar.rrec@gmail.com

Website: www.energy.rajasthan.gov.in/rrec

No. RSDCL/D(T)/Tr. Lines/SP/TK/TN No. 02/2019-20/D *267* Date *04/02/2020*

Sub: Addendum/Corrigendum/Clarification No. 01 in the tender documents for Construction of 220kV & 132kV Tr. Lines on Turnkey basis for Nokh Solar Park under Specification No. RSDCL/D(T)/Tr. Lines/SP/TK/TN No. 02/2019-20.

Ref: Pre bid meeting dated 31.01.2020 held at RSDCL, Jaipur.

An Addendum/Corrigendum No. 01 in the tender documents for construction of 220kV & 132kV Tr. Lines on Turnkey basis for Nokh Solar Park under Specification No. RSDCL/D(T)/Tr. Lines/SP /TK / TN No. 02/2019-20 alongwith the clarification of queries of firms as per attached document is hereby issued for the reference of interested bidders. The bidders may go through the attached documents before completing & uploading their online bids.

Encl: As above.

S.R.
4/2/2020
(S.R. Mahalda)
Director (Technical)
RSDCL, Jaipur

Addendum/Corrigendum No. 01

Construction of 220kV & 132kV Tr. Lines on Turnkey basis for Nokh Solar Park under Specification No. RSDCL/D(T)/Tr. Lines/SP /TK / TN No. 02/2019-20

An Addendum /Corrigendum No. 01 in BoQ of this tender (TN No. 02/2019-20) as detail hereunder is hereby issued for the interested bidders:

1) **BoQ-1 (Supply of items for 220kV Tr. Lines):**

The bidder has to quote the rates for Sr. No. 27 (Item No. J), 28 (Item No. K) & 29 (Item No. L) by considering the item as under:

“vibration damper with armour rod”.

2) **BoQ-2 (Supply of items for 132kV Tr. Line):**

The bidder has to quote the rates for Sr. No. 21 (Item No. A) - “Suspension Assembly with vibration damper” and for Sr. No. 22 (Item No. B) - “Tension Assembly with vibration Damper”.

dy

su

sz

SA

Statement of Pre Bid Queries received from bidders for Construction of 220kV & 132kV Tr. Lines on Turnkey basis for Nokh Solar Park under Specification No. RSDCL/D(T)/Tr. Lines/SP/TK/TN No. 02/2019-20

S. No.	Firm Name	Bid Documents Clause No.	Specification Clause	Firm's Request for Consideration	RSDCL Comments
1	Ashoka Buildcon Ltd., Nashik-422009	Technical Eligibility Criteria	<p>(i) EXPERIENCE: The bidder should have successfully surveyed, optimized tower locations and based thereon erected & strung, not less than 80% of the route length of tendered (75.85 Kms) Transmission lines of 132kV or higher voltage class on turnkey basis, cumulatively, which includes Engineering, Procurement & Construction of line(s) within the last seven years immediately preceding the date of technical bid opening.</p>	<p>(i) EXPERIENCE: The bidder should have successfully surveyed, optimized tower locations and based thereon erected & strung, not less than 50% of the route length of tendered (75.85 Kms) Transmission lines of 132kV or higher voltage class on turnkey basis, cumulatively, which includes Engineering, Procurement & Construction of line(s) within the last seven years immediately preceding the date of technical bid opening.</p>	Change in experience under qualifying requirement is not acceptable.
		Joint Venture Criteria Technical Criteria	<p>TECHNICAL CRITERIA</p> <p>(i) The lead partner of the joint venture should have successfully surveyed, optimized tower locations and based thereon erected & strung at least 50% of the route length of tendered transmission lines of 132kV or higher voltage class, cumulatively, within last seven years immediately preceding the date of</p>	Any partner of the joint venture can fulfil the 100% technical criteria.	Meeting 100% technical criteria by any partner of joint venture is not acceptable.

ky

1

al

al

al

			<p>Technical bid opening as EPC contractor.</p> <p>(ii) The other partner should have 50% of tower manufacturing capacity and should have manufactured/supplied 50% of the complete tower parts as given in clause No. 1.14.1(ii).</p> <p>Alternatively, he may have experience of EPC contracts of transmission lines of 132kV or of higher voltage class and/or EHV Grid Sub-stations within last seven years immediately preceding the date of Technical bid opening.</p> <p>(iii) The joint venture partners should collectively meet the qualifying requirements stipulated at clause No. 1.14.1.</p>	<p>Kindly Confirm, whether this project is funded by RSDCL or by any funding agency? If it is funding agency, kindly provide the name.</p>	<p>Query raised by the firm is irrelevant. Payment terms shall be as per tender document.</p>
2.	Teems India Towerline Pvt. Ltd., Chennai-600096	13.0 - Mode of Payment for Supply of Material & 14.0 Mode of Payment for Survey & Erection Parts	<p>Clause mentioned that, "The Payment shall be made by Paying authority"</p>		

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

<p>13.0 - Mode of Payment for Supply of Material & 14.0 Mode of Payment for Survey & Erection Parts</p>	<p>Clause mentioned that, "The Payment shall be made by Paying authority within a reasonable period from the date of receipt of the Contractor's bills/invoices".</p>	<p>Please confirm, what will be the maximum days for making payment from the date of submission of Contractor's bills/invoices.</p>	<p>The time period for making the payment has already been mentioned in the tender document itself.</p>
<p>12.7.4 Taxes and Duties</p>	<p>Taxes & duties including GST applicable as per Indian Tax laws, in respect of transaction between the Company and Contractor shall be paid by Company as per the Contract after each shipment against submission of invoices & documentary evidence as applicable. Payment towards taxes & duties including GST shall be released by Company directly to the Contractor.</p>	<p>Kindly clarify whether GST is paid along with running bills or GST will be reimbursed later?</p>	<p>The provision of GST is clarified in tender document.</p>
<p>1.03 Bid Guarantee (Bid Security)</p>	<p>Clause mentioned that, 20% amount of Bid Security (EMD) shall be deposited by bank Demand Draft/Banker's Cheque along with bid Bank Guarantee of balance 80% amount.</p>	<p>Please confirm, can we submit the 100% EMD amount in the form of Bank Guarantee?</p>	<p>EMD shall be as per tender document i.e. 20% in cash & remaining 80% in the form of BG. Firm's request not acceptable.</p>
<p>1.01 Introduction : Section-1 Instructions To Bidders</p>	<p>Clause mentioned that, "Before submitting the bids, the bidders may verify the site & assess the tendered works".</p>	<p>Please give us the contact details for commencing our Pre Tender-Site Visit.</p>	<p>He may contact Sh. Surendra Kumar Mathur, Project Manager, RREC, Jaisalmer. Contact No. 9057221332.</p>
<p>1.14.1 Technical Criteria: (1)</p>	<p>Clause mentioned that, The bidder should have successfully surveyed, optimized tower locations and based thereon erected & strung, not less</p>	<p>We have completed many 110kV Transmission Line Turnkey Projects involving ACSR Panther with TANTRANSCO (State Power</p>	<p>Experience of 110kV Tr. System is not considerable against the work experience of 132kV & above voltage</p>

3	Jakson, Noida, U.P.	Tender Notice- Section III (A)	Experience than 80% of the route length of tendered (75.85 Kms) Transmission lines of 132kV or higher voltage class on turnkey basis.	Utility) which is similar design as 132kV. Kindly confirm, whether 110kV Transmission line Experience will be considered as 132kV in Technical Evaluation.	class Tr. lines.
	Tender Notice- Annexure -I		Approved makes for the following items are missing from the tender, Please arrange the same. "1. Tower Structure 2. OPGW Hardware Fittings and Accessories"	Principal Technical Parameters of ACSR Panther conductor are given at Appendix-1. Nut Bolts, Washers, etc are the part of towers and are to be supplied as per relevant ISS and tender document. The bidder has to furnish his own confirmation of having access for all the requisite material from approved vendors. 1. The Make of tower structure shall be as per the manufacturing capacity of its supplier. 2. Hardware Fittings and Accessories of OPGW shall be of type tested design. Yes.	
	Tender Notice-	12. The prices quoted for all the items mentioned in the tender	The type test reports for all the hardware fittings & accessories for conductor and earth wire, nut bolts, step bolts, spring washer, earth wire has to be submitted after the bidder becomes a successful bidder. Please confirm. The prices quoted for all the items mentioned in the tender	No price variation shall be allowed.	






	General Detailed Works, Clause no. 12	document shall be firm only and no any price variation shall be allowed.	document shall have price variation. Please confirm	
4.	VM Infra Projects Pvt. Ltd., Vaishali Nagar, Jaipur.		The technical criteria for both JV partners please consider the only lead partner's technical and consider second partner only for financial support. If you consider both partner's technical criteria there is no mean of joint venture.	JV terms & conditions shall be as per tender document only.
5.	M/s Sonaa Engineers Pvt. Ltd., Jaipur.		As per RTPP rule 42 concessional bid security has to be given by MSME registered organisations, whether this rule would be applicable for this tender.	All the bidders have to furnish full security as per tender document.
			Clarification in BoQ is required for use of disc insulator in place of long rod and vice versa and where to quote rates for these items.	Bidder has to quote the rate for long rod insulator (string) only.
			Whether advance BG can be released once advance is set off or if any alternate BG is given in lieu of residual advance, can the advance BG furnished be discharged.	The provisions of tender document will prevail.
			We request you to please provide separate closure of each line as commissioning of each line is separately done.	The closure of complete contract shall be as per tender document only.
			Clarification required for vibration dampers, MSC joints and Repair Sleeves in 132kV Tr. Lines.	A separate addendum/ Corrigendum (No. 01) is being issued.




