

Form G 2.2
Operational Parameters - Generation

Rajasthan Rajya Vidyut Utpadan Nigam Ltd.
GLPL Unit-2

S. No.	Particulars	Units	2010-11	2011-12	2012-13	2013-14
1	2	3	4	5	6	7
2	Operational Parameters - Thermal					
2.1	Total Capacity	MW	125	125	125	125
2.2	Plant Load Factor	%	70.00%	70.13%	72.63%	75.13%
2.3	Gross Generation	MU	42.00	770.03	795.30	822.67
2.4	Auxiliary Energy Consumption	%	11.50%	11.50%	11.50%	11.50%
2.5	Auxiliary Energy Consumption	MU	4.83	88.55	91.46	94.61
2.6	Net Generation	MU	37.17	681.47	703.84	728.07