

Rajasthan Rajya Vidyut Utpadan Nigam Ltd.

Performance of RRVUNL Power Stations of FY-2009-10

S. No.	Name of Power Station	Capacity (MW)	Gross Generation (MU)	PLF (%)	Gen. Loss (due to B/D by SLDC) (MU)	Deemed Gross Generation (MU)	Deemed PLF (%)	Aux. Consumption (%)	Net Generation (MU)	Sp. Oil Consumption (ml/ kwh)	Sp. Coal Consumption (kg/ kwh)	Sp. Gas Consumption (SCM/kwh)	SHR (kcal/kwh)	Availability (%)
1	SSTPS	1500	9192.41	79.94	154.83	9347.24	81.29	9.17	8349.40	1.02	0.67	2476	83.78
2	KSTPS	1240	8584.32	89.65	72.35	8656.67	90.40	9.54	7763.25	0.70	0.68	2584	88.94
3	CTPP	-	246.92	22.61	0.00	246.92	22.61	17.79	203.00
4	DCCPP	330	2424.75	83.88	0.00	2424.75	83.88	2.49	2364.37	0.24	2110	93.48
5	GLPL	250	665.17	30.37	0.00	665.17	30.37	18.03	545.27	2.21	1.15	3515	51.54
6	RGTPP	113.5	353.99	36.57	0.00	353.99	36.57	7.88	326.09	0.26	0.64	2514	61.66
7	MAHI	140	85.19	6.95	0.00	85.19	6.95	1.13	84.22
8	MMH	23.85	5.68	2.72	0.00	5.68	2.72	3.42	5.49
9	RPS	172	143.87	9.55	0.00	143.87	9.55	0.33	143.39
10	JS	99	117.23	13.52	0.00	117.23	13.52	0.28	116.91
TOTAL			21819.52		227.18	22046.71			19901.39					