

Rajasthan Rajya Vidyut Utpadan Nigam Ltd.

Performance of RRVUNL Power Stations of FY-2010-11

S. No.	Name of Power Station	Capacity (MW)	Gross Generation (MU)	PLF (%)	Gen. Loss (due to B/D by SLDC) (MU)	Deemed Gross Generation (MU)	Deemed PLF (%)	Aux. Consumption (%)	Net Generation (MU)	Sp. Oil Consumption (ml/ kwh)	Sp. Coal Consumption (kg/ kwh)	Sp. Gas Consumption (SCM/kwh)	SHR (kcal/kwh)	Availability (%)
1	SSTPS	1500	9409.78	71.61	504.34	9914.12	75.45	9.12	8551.18	1.34	0.67	2493	77.15
2	KSTPS	1240	9891.47	91.06	343.76	10235.23	94.23	9.67	8935.21	0.57	0.67	2465	92.42
3	DCCPP	330	1991.20	68.88	2.65	1993.85	68.97	2.66	1938.28	0.23	2126	82.29
4	CTPP	250	971.36	55.07	61.32	1032.68	58.74	11.35	861.07	5.38	0.64	2996	64.99
5	GLPL	250	596.58	27.24	0.00	596.58	27.24	18.58	485.00	2.54	1.19	3751	49.65
6	RGTPP	113.5	302.89	31.29	0.00	302.89	31.29	5.30	286.74	0.68	0.61	2693	54.99
7	MAHI	140	69.26	5.65	0.00	69.26	5.65	1.13	68.48
8	MMH	23.85	10.96	5.25	0.00	10.96	5.25	0.22	10.74
9	RPS	172	174.39	11.57	0.00	174.39	11.57	0.24	173.97
10	JS	99	146.33	16.87	0.00	146.33	16.87	0.23	145.99
TOTAL			23564.22		912.07	24476.29			21456.66					