

Rajasthan Rajya Vidyut Utpadan Nigam Ltd.

Performance of RRVUNL Power Stations of FY-2012-13

S. No.	Name of Power Station	Capacity (MW)	Gross Generation (MU)	PLF (%)	Gen. Loss (due to B/D by SLDC) (MU)	Deemed Gross Generation (MU)	Deemed PLF (%)	Aux. Consumption (%)	Net Generation (MU)	Sp. Oil Consumption (ml/ kwh)	Sp. Coal Consumption (kg/ kwh)	Sp. Gas Consumption (SCM/kwh)	SHR (kcal/kwh)	Availability (%)
1	SSTPS	1500	10570.32	80.44	847.42	11417.75	86.89	9.05	9613.85	1.06	0.65	2540	88.70
2	KSTPS	1240	9739.64	89.66	301.45	10041.09	92.44	9.48	8815.97	0.40	0.64	2526	90.19
3	CTPP	500	2924.17	66.76	291.44	3215.61	73.42	10.69	2611.60	1.65	0.64	2708	74.60
4	DCCPP	330	1162.43	40.21	13.60	1176.03	40.68	3.36	1123.35	0.26	2444	49.34
5	RGTPP	113.5	497.91	51.44	15.13	513.04	53.00	1.48	490.52	0.12	0.55	2572	69.79
6	GLPL	250	471.96	21.55	0.00	471.96	21.55	21.61	369.97	2.20	1.25	3775	44.91
7	MAHI	140	204.18	16.65	0.00	204.18	16.65	0.70	202.75
8	MMH	23.85	17.53	8.39	0.00	17.53	8.39	1.30	17.30
9	RPS	172	366.03	24.29	0.00	366.03	24.29	0.13	365.57
10	JS	99	275.09	31.72	0.00	275.09	31.72	0.10	274.80
TOTAL			26229.25		1469.04	27698.30			23885.69					