

**Rajasthan Rajya Vidyut Utpadan Nigam Ltd.**

**Performance of RRVUNL Power Stations for FY-2018-19**

S. No.	Name of Power Station	Capacity (MW)	Gross Generation (MU)	PLF (%)	Gen. Loss (due to SLDC) (MU)	Deemed Gross Generation (MU)	Deemed PLF (%)	Aux. Consumption (%)	Net Generation (MU)	Sp. Oil Consumption (ml/ kwh)	Sp. Coal Consumption (kg/ kwh)	Sp. Gas Consumption (SCM/kwh)	SHR (kcal/kwh)	Availability (%)
1	SSTPS	1500	7168.99	54.56	4867.19	12036.18	91.60	10.01	6451.61	0.696	0.599	-	2476.15	91.76
2	KSTPS	1240	7920.96	72.92	1655.71	9576.67	88.16	11.00	7049.45	0.404	0.673	-	2614.14	85.55
3	KaSTPP	1200	5550.40	52.80	738.70	6289.10	59.83	6.66	5180.60	0.770	0.562	-	2435.28	61.75
4	CTPP	1000	7289.83	83.22	523.71	7813.54	89.20	9.47	6599.27	0.377	0.566	-	2549.03	89.38
5	CSC TPP	660	2714.18	72.91	104.00	2818.18	75.71	6.80	2529.56	1.243	0.584	-	2771.76	94.20
<b>TOTAL (1+2+3+4+5)</b>		<b>5600</b>	<b>30644.35</b>	<b>65.21</b>	<b>7889.31</b>	<b>38533.67</b>	<b>81.99</b>	<b>9.25</b>	<b>27810.49</b>	-	-	-	-	<b>84.53</b>
6	DCCPP	330	20.93	0.72	2280.67	2301.60	79.62	90.34	2.02	-	-	0.296	2725.67	81.95
7	RGTPP	273.5	998.06	42.12	4.25	1002.30	42.30	4.26	955.57	0.003	-	0.413	2465.99	68.54
8	GLPL	250	0.00	0.00	0.00	0.00	0.00	#DIV/0!	0.00	0.000	0.000	-	0.00	0.00
9	MAHI	140	117.06	9.54	-	-	-	1.00	115.89	-	-	-	-	-
10	MMH	23.85	4.73	2.27	-	-	-	3.53	4.57	-	-	-	-	-
11	RPS	172	334.03	22.17	-	-	-	0.10	333.68	-	-	-	-	-
12	JS	99	246.79	28.46	-	-	-	0.11	246.52	-	-	-	-	-
<b>TOTAL (RRVUNL)</b>			<b>32365.95</b>	-	<b>10174.23</b>	<b>41837.57</b>	-	-	<b>29468.72</b>	-	-	-	-	-