



RAJASTHAN RAJYA VIDYUT UTPADAN NIGAM LIMITED

Corporate Identity Number (CIN)- U40102RJ 2000SGC016484
Regd. Office & H.O. Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

OFFICE OF THE SUPERINTENDING ENGINEER (MM),
CHHABRA SUPERCRITICAL THERMAL POWER PROJECT

Plant Site, Chowki Motipura, Chhabra, Dist. Baran-325220


Email ID: xenmmcsctpp@gmail.com

Website: energy.rajasthan.gov.in/rvunl

No. RRVUNL / SE (MM) / CSCTPP / Chhabra / F. / D. 1060 Date: 14/11/2019

CORRIGENDUM-I

Addendum in the Section of Details of Technical Specifications of Tender Documents of **TN-SC-338/2019-20(MM)** for Supply of Fin Flats for boiler furnace unit # 5&6 (2x660 MW) at CSCTPP, Chhabra (Raj.) .The Technical specification for Fin Flats for boiler furnace may now be read with following additions as under :-



Technical Specification

1. Material :- SA387-12-1(SA 387 grade 12 class 1)
2. Chemical Composition of SA 387 Alloy steel Gr.12 Cl.1 Plate (According to ASME Specification)

Carbon	Manganese	Phosphorous	Sulphur	Silicon	Chromium	Molybdenum
0.04%-0.17%	0.35%-0.73%	0.035%	0.035%	0.13%-0.45%	0.74%-1.21%	0.4%-0.65%

Required conditions:-

1. Firm should material test certificate from Govt. Approved lab.
2. Supplied material will be tested by RRVUNL at the cost of supplier by Govt. approved Lab. After confirmation of material payment will be made.

Rest of the conditions remain unchanged.

(N. S. Khangrot)

**SUPERINTENDING ENGINEER (MM)
CSCTPP, RRVUNL, Chhabra**

Copy submitted / forwarded to the following for information & necessary action please:-

1. The Chief Engineer, CSCTPP, RRVUNL, Chhabra.
2. The Addl.Chief Engineer (E&M), CSCTPP, RRVUNL, Chhabra.
3. The Accounts Officer, CSCTPP, RRVUNL, Chhabra.
4. The Executive Engineer (MM), CSCTPP, RRVUNL, Chhabra.
5. O/c

**SUPERINTENDING ENGINEER (MM)
CSCTPP, RRVUNL, Chhabra**