

RAJASTHAN RAJYA VIDYUT UTPADAN NIGAM LTD.

Corporate Identity Number (CIN) – U40102RJ200

Office of the Chief Engineer

RAMGARH GAS THERMAL POWER STATION, RAMGARH- Distt.- JAISALMER

Postal Add. : Opp. Main Post Office, Hanuman Chauraha, Jaisalmer

Phone: 9413385481, 9413349029, E-mail: seprocrgtpp@gmail.com



No. RVUNL / RGTPP / RMG / CE / F. /D3480DATE30.01.19

CORRIGENDUM- III

The following details are added with the technical specification of subject tender no. TN-580

IMPORTANT INSTRUCTIONS/INFORMATIONS FOR BIDDERS

1. Breakup of I/O's of existing GT DCS in the ANNEXURE-IV of technical specification is as follows

General I/O's for each GT DCS

Sr.No.	Signal type	Quantity
1.	DI	179
2.	DO	89
3.	T/C	66
4.	RTD	02
5.	AI	15
6.	AO	03
Total		354

Turbine specific I/O's for each GT DCS

Sr.No.	Signal type	Quantity
1	Vibration sensor	11
2	LVDT's	06
3	Flame scanner	04
4	Speed sensor	10
5	Servo command	04

Total	35
-------	----

2. Gas Flow meters shall be required of turbine type with 0.5% accuracy or higher
3. Standards and specifications for Signal / Instrumentation cables shall be as per specification as GTs are of GE make, USA. Also pairing of cables shall be as per ANNEXURE-VIII.
4. Specifications of only 4 type of skid cables are given as available in the ANNEXURE-IX, but contractor must supply all 11 type of skid cables on the basis of GE Part Nos. Bidders may visit RGTPP, Ramgarh site for more assessment in this reference.

SUPERINTENDING ENGINEER (O&M-II)
RGTPP, RVUNL, RAMGARH